

Government of India
Department of Atomic Energy
General Services Organisation
Engineering Services Group
Electrical and Mechanical Services Division

GSO/ESG/E&MSD/EMS/SSPL/VCBP/PC /2021

Kalpakkam
24.05.2021

TO WHOMSOEVER IT MAY CONCERN

This is to certify that, M/s S&S POWER SWITCHGEAR LTD., CHENNAI, INDIA has supplied the following Circuit Breakers to **M/s General Services Organisation, DAE Township, Kalpakkam**, against P.O. No. 743 Dated 21.11.2018, through M/s. Sree Raghavendra Electric Services Private Limited.

S&S Make, 11 kV, 630A, 13.1 kA/1 sec, Indoor vacuum circuit breaker panel (Type HHV12).

With Closing/Tripping coil voltage: 110Volts DC

The details of feeders are

- Outgoing Feeders – 4 Nos
- Transformer Feeder – 1 No

The above Circuit Breaker has been commissioned in March 2020 and Performance of these VCB's are found to be satisfactory.



26/5/2021
R. Nagarajan

Engineer In Charge (EC & M),
E & MSD, ESG, GSO.

आर. नागराजम / R. Nagarajan
प्रभारी अभियंता (ईसी एंड एम) / Engineer-In-Charge (EC & M)
विद्युत एवं यांत्रिक सेवा प्रभाग
Electrical & Mechanical Services Division,
अभियांत्रिकी सेवा समूह / Engineering Services Group
सामान्य सेवा संगठन / General Services Organization
परमाणु ऊर्जा विभाग / Department of Atomic Energy
भारत सरकार / Government of India
कल्पक्कम / Kalpakkam-603 102