



**Oil and Natural Gas Corporation Ltd.**  
**Captive Power Plant – Geleky**  
**Assam Asset**

**WORK COMPLETION CERTIFICATE**

Date:- 31.01.2016

This is to certify that following job has been satisfactorily carried out by M/s S&S Power Switchgear Ltd, Chennai in all respects with respect to the Order No: No. NZR/CPP/CON-293/S&S Panel/2013-14 Date: 13.09.2014 & Amendment no. NOA No. NZR/CPP/CON-293/S&S Panel /2015-16/03 dated 06.01.2016

Details of Work Order / P.O:


SL	ITEM	DESCRIPTION
1	Subject:	On-site Overhauling / repairing of 11KV indoor S&S make Vacuum circuit breakers (VCB) and strengthening of bus bar insulators of S&S KV panel at Assam Asset, ONGC
2	Work Order No: and Date:	No. NZR/CPP/CON-293/S&S Panel/2013-14 Date: 13.09.2014 & Amendment no. NOA No. NZR/CPP/CON-293/S&S Panel /2015-16/03 dated 06.01.2016
3	Completion Date:	30.01.2016
4	Vendor:	M/s S&S Power Switchgear Ltd, Chennai

Details of Work:

02 nos. of engineers of M/s S&S Power Switchgear Ltd, Chennai visited the site. All mandatory spares were replaced and overhauling/servicing of 11KV S&S breaker and strengthening of Bus bar Insulator, testing were carried out.

All the jobs as per the scope of the said Work Order were carried out completely. The workmanship of the engineers were satisfactory.

  
31/01/2016  
S.K. Vatsa  
Installation Manager  
CPP Geleky

  
31.01.16  
Piyush Choudhary  
SE(E) – CPP Geleky



  
**J.A. SELVAKUMAR**  
ADVOCATE & NOTARY PUBLIC  
New No.344, Old No.162,  
Thambu Chetty Street, Chennai – 600 001.

